



**WIRING INFORMATION**

LINE VOLTAGE  
 -FACTORY STANDARD \_\_\_\_\_  
 -FACTORY OPTION - - - - -  
 -FIELD INSTALLED - - - - -

LOW VOLTAGE  
 -FACTORY STANDARD - - - - -  
 -FIELD INSTALLED - - - - -

REPLACEMENT WIRE  
 -MUST BE THE SAME SIZE AND TYPE OF INSULATION AS ORIGINAL (105C. MIN.)

WARNING  
 -CABINET MUST BE PERMANENTLY GROUNDED AND CONFORM TO I.E.C., N.E.C., C.E.C., NATIONAL WIRING REGULATIONS, AND LOCAL CODES AS APPLICABLE.

**NOTES**

① REFER TO SPEC. SHEET FOR ACTUAL FACTORY MOTOR TAP PLACEMENT OF "HEAT" & "LOW", AS SOME MODELS MAY BE DIFFERENT THAN SHOWN HERE. ALSO, REFER TO SPEC. SHEET OR INSTALLATION MANUAL IF WIRING OF HEAT AND/OR COOL SPEEDS IS NOT DESIRABLE.

② CONNECT UNUSED MOTOR LEADS TO M1 AND/OR M2.

③ MODELS WITH 3 SPEED MOTOR - BLUE LEAD IS FOR MEDIUM SPEED NO YELLOW LEAD ON MOTOR

**COMPONENT CODES**

BR BLOWER RELAY  
 CC COMPRESSOR CONTACTOR  
 CT CONTROL TRANSFORMER  
 DISC DISCONNECT SWITCH  
 EAC ELECTRIC AIR CLEANER  
 FR FAN RELAY  
 FS FLOW SWITCH  
 FU FUSE  
 GND GROUND  
 HUM HUMIDIFIER RELAY  
 IBM INDOOR BLOWER MOTOR  
 PBS PUSH BUTTON SWITCH  
 PL PLUG  
 PR PUMP RELAY  
 RC RUN CAPACITOR  
 TH THERMOSTAT (H/C)  
 WIRE NUT

**WIRE COLOR CODE**

BK.....BLACK	G.....GREEN	PR.....PURPLE
BR.....BROWN	GY.....GR AY	R.....RED
BL.....BLUE	O.....ORANGE	W.....WHITE
	Y.....YELLOW	

**ELECTRICAL WIRING DIAGRAM**

**ELECTRICAL WIRING DIAGRAM**

**HYDRONIC AIR HANDLER**

**PSC MOTOR**

**NO PUMP**

APPROVED:	CHECKED:	ORIGINAL RELEASE NO.:
MODELED BY: <b>MBA</b>	DATE: <b>11-24-15</b>	<b>H-10255024</b>
PART NO.: <b>90-103346-07</b>		REV: <b>01</b>